



# XHGK7.R21933 - CABINETS CERTIFIED FOR CANADA

## Cabinets Certified for Canada

See General Information for Cabinets Certified for Canada

### IN-O-VATE TECHNOLOGIES

R21933

810 Saturn St, Suite 20

Jupiter, FL 33477 USA

Dryerbox Models 350, 425, 480, 3D, and 4D for use in through-penetration firestop system described in Volume 2 of the UL Fire Resistance Directory. The specific System No. and the applicable rating information is as follows:

System No.	Rating Hr			
	F	FT	FH	FTH
W-L-7129	1/2 and 1	1/2 and 1	1/2 and 1	1/2 and 1

Last Updated on 2015-10-06

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"